# Honeywell

# N05, N10 SERIES

NON-SPRING RETURN DIRECT-COUPLED DAMPER ACTUATORS FOR FLOATING AND TWO-POSITION CONTROL

#### **PRODUCT DATA**



### GENERAL

This non-spring return direct-coupled damper actuator provides floating and two-position control for:

- air dampers,
- VAV units,
- air handlers,
- ventilation flaps,
- louvers, and
- reliable control for air damper applications with up to 10 sq ft / 44 lb-in. (5 Nm) and 20 sq ft / 88 lb-in. (10 Nm) (sealless damper blades; air friction-dependent).

### FEATURES

- Declutch for manual adjustment
- Adjustable mechanical end limits
- Removable access cover for direct wiring
- Mountable in any orientation
- Rotation direction and service/OFF switch

### **SPECIFICATIONS**

Supply voltage MN6105/MN6110

24 Vac/dc -15%/+20%, 50/60 Hz

-5...+140 °F (20...+60 °C)

5...95%, non-condensing

II as per EN 60730-1

-22...+176 °F (-30...+80 °C)

Nominal voltage MN6105/MN6110 24 Vac/dc, 50/60 Hz

All values stated hereinafter apply to operation under nominal voltage conditions.

5 VA / 2 W

IP54

60000

1.5 million

3/8 in...5/8 in.

min. 1-5/8 in.

5° / 85°

95° <u>+</u> 3°

1/4 in...1/2 in.; 45° steps

44 lb-in. (5Nm) / 88 lb-in. (10 Nm)

Ш

Power consumption MN6105/MN6110

Ambient limits Ambient operating limits Ambient storage limits Relative humidity

Safety Protection standard Protection class Overvoltage category

Lifetime Full strokes Repositions

**Mounting** Round damper shaft Square damper shaft Shaft length

End switches (when included) Rating Class II

Triggering points

Torque rating

Runtime for 90° MN6105 MN6110

Rotation stroke

Dimensions

Noise rating

Weight (without cables) 1 lbs.

35 dB(A) max. at 1 m

90 sec (dc / 60 Hz ac)

90 sec (dc / 50 Hz ac)

see "Dimensions" on page 6


® U.S. Registered Trademark Copyright © 2005 Honeywell Inc. All rights reserved





EN0B-0544GE51 R0805

### PRODUCT IDENTIFICATION SYSTEM



### **BASIC FEATURES**




Fig. 1. Setting units and control elements

#### Legend for Fig. 1:

- 1) Universal shaft adapter
- 2) Mechanical end limits (manually adjustable)
- 3) Declutch button
- 4) Function selection switch
- 5) Removable access cover
- 6) Anti-rotation bracket

#### **Contents of Package**

The delivery package includes the actuator, parts 1 through 6 (see Fig. 1), plus two cable grommets and a spare cable grommet.

### **RUN MODES**

The function selection switch (see Fig. 2) can be used to place the actuator into any one of two different modes:

• Service/Off; or

•

the floating/2-position run mode ("Dir" for CCW-closing dampers or "Rev" for CW-closing dampers). FLOATING/2-POSITION SERVICE/OFF



Fig. 2. Function selection switch

### **Power-Off Behavior**

If power is removed, the shaft adapter remains in position.

### Service/Off

If the function selection switch is set to the "Service/Off" position, then all rotary movement is cancelled, and all control signals are ignored, thus allowing the actuator to be manually operated safely.

### Floating/2-Position Run Mode

If the function selection switch has been set to one of the two floating/2-position control settings—and if the actuator is wired correspondingly (see Fig. 7, Fig. 8, and Fig. 9)—then as soon as operating power is applied, the shaft adapter will run according to the control signals applied.

Table 1 describes the behavior ("stops," rotates "CCW," or rotates "CW") of the MN6105/MN6110 in dependence upon the control signals (switch "open" or "24 Vac/dc") applied to terminals 3 and 4, the function selection switch setting, and the manner in which the actuator is wired (either for floating mode: see Fig. 7; or for 2-position mode: see Fig. 8).

 Table 1. Behavior of MN6105/MN6110

|        | control signal at |          | switch setting |                 |       |
|--------|-------------------|----------|----------------|-----------------|-------|
| wiring | term 3            | term 4   | Dir            | Service/<br>Off | Rev   |
| float. | open              | open     | stops          | stops           | stops |
|        | open              | 24Vac/dc | CCW            | stops           | CW    |
|        | 24Vac/dc          | open     | CW             | stops           | CCW   |
| 2-pos. | 24Vac/dc          | open     | CW             | stops           | CCW   |
|        | 24Vac/dc          | 24Vac/dc | CCW            | stops           | CW    |

### MANUAL ADJUSTMENT

#### IMPORTANT

To prevent equipment damage, before manual adjustment, you must remove power or set the function selection switch to the "Service/Off" position.

After removing power or setting the function selection switch to the "Service/Off" position, the gear train can be disengaged using the declutch button, permitting the shaft adapter to be manually rotated to any position.

#### Limitation of Rotation Stroke

Two adjustable mechanical end limits are provided to limit the angle of rotation as desired (see Fig. 3). The mechanical end limits must be securely fastened in place.




Fig. 3. Mechanical end limits

To ensure tight closing of the dampers, the shaft adapter has a total rotation stroke of  $95^{\circ}$ .

### **INTERNAL END SWITCHES**

The internal end switches "A" and "B" are changeover switches which are activated when the shaft adapter moves past a position of  $5^{\circ}$  and  $85^{\circ}$ , respectively (see also Table 3).



Fig. 4. Internal end switch triggering points

### INSTALLATION

# 

To avoid personal injury (electrical shock) and to prevent equipment damage, before installation, you must remove power.

These actuators are designed for single-point mounting.

#### **Mounting Instructions**

All information and steps are included in the Installation Instructions (Product Literature No. 62-0224) supplied with each actuator.

### **Mounting Position**

The actuators can be mounted in any position (IP54 is dependent upon orientation; see Fig. 8). Choose a mounting position permitting easy access to cables and controls.




Fig. 5. Mounting for IP54

NOTE: Further, in order to guarantee IP54, only original Honeywell grommets may be used.

### **Anti-Rotation Bracket and Screws**

If the actuator is to be mounted directly on a damper shaft, use the anti-rotation bracket and screws included in the delivery package. The min. distance between the center of the damper shaft and the middle of the anti-rotation bracket is 3.35 in.; a max. of 4.25 in. is allowed (see also Fig 10).

Depending upon the specifics of your mounting site, the actuator may shift in position slightly while tightening the screws at the top of the shaft adapter. The anti-rotation bracket features a T-piece with a 5-mm-long shank to accommodate for this movement. It is important to ensure that this play is not impeded.

### **Universal Shaft Adapter**

The universal shaft adapter can be used for shafts of various diameters and shapes (round: 3/8...5/8 in. and square: 1/4...1/2 in.).

### WIRING




To avoid personal injury (electrical shock) and to prevent equipment damage, before wiring, you must remove power.


#### **Access Cover**

#### IMPORTANT

Once the access cover has been removed, please take care to avoid damaging any of the parts now accessible.

The access cover can be unscrewed and removed in order to gain access to the terminal block(s) and perform wiring.





### Wiring Diagrams




Fig. 7. MN6105/MN6110 (floating mode)




Fig. 8. MN6105/MN6110 (2-position mode)




Fig. 9. End switches

#### Table 3. Internal end switches

| terminal | type of switch   |  |
|----------|--|--|
| S1       | common lead for switches A and B   |  |
| S2/S3    | change-over switch A (S1/S2 opens and S1/S3 closes when shaft adapter moves CW past 5°; reverts to original state when shaft adapter moves CCW past 5°). |  |
| S5/S6    | change-over switch B (S1/S6 closes when shaft adapter moves CW past 85°; reverts to original state when shaft adapter moves CCW past 85°).               |  |

NOTE: Both internal end switches must be connected to the same power source.

Tables 2 and 3 summarize the information presented in the preceding wiring diagrams.

| ter-<br>minal  | signal in floating           | signal in 2-pos. mode               |  |  |
|--|------------------------------|-------------------------------------|--|--|
| 2  | common ~/-                   | common ~/-                          |  |  |
| 3  | 24 V ~/+<br>(control signal) | 24 V ~/+<br>(control/ power signal) |  |  |
| 4  | 24 V ~/+<br>(control signal) | 24 V ~/+<br>(control signal/power)  |  |  |
| NOTE: All cables connected to these terminals must be equipped with spark suppression. |                              |                                     |  |  |

N05, N10 SERIES DAMPER ACTUATORS FOR FLOATING/2-POSITION CONTROL

### DIMENSIONS




Fig. 10. Dimensions (in in.)

N05, N10 SERIES DAMPER ACTUATORS FOR FLOATING/2-POSITION CONTROL

N05, N10 SERIES DAMPER ACTUATORS FOR FLOATING/2-POSITION CONTROL

#### **Automation and Control Solutions**

Honeywell International Inc. 1985 Douglas Drive North Golden Valley, MN 55422 customer.honeywell.com Honeywell Limited-Honeywell Limitée 35 Dynamic Drive Scarborough, Ontario M1V 4Z9

® U.S. Registered Trademark
 © 2005 Honeywell International Inc.
 63-2632 EN0B-0544GE51 R0805
 A.A. Rev. 08-05



Printed in U.S.A. on recycled paper containing at least 10% post-consumer paper fibers.

## Honeywell